



- \*Sonar Pipe Notes:**
- Sonar pipe can be purchased from Dynamic Monitors if desired.
  - If customer supplied, use nominal 2" pressure rated pipe O.D = 2.375"
  - Clear SCHD40 recommended so the inside can be easily inspected for debris.



**DYNAMIC**  
MONITORS.COM

1-888-747-7645 Toll Free

PROJECT:		SEPTIC SITTER™ INSTALLATION		JOB NO		NA	
TITLE							
LEACHING CHAMBER WITH VALVE BOX							
SCALE	FILE	CHK	DRAWN BY	DATE			
NTS	D-102	KAG	SCR	Feb 19, 2017			